

PART I: GOOD REPAIR STANDARD

(X). If underlined statement is not true, then this is an extreme deficiency (marked as an "X") on the Evaluation Detail resulting in a "poor" rating for the applicable category.

Gas Leaks

Gas systems and pipes appear safe, functional, and free of leaks.
Examples include but are not limited to the following:

- a. There is no odor that would indicate a gas leak. (X)
- b. Gas pipes are not broken and appear to be in good working order. (X)
- c. Other

Mechanical Systems

Heating, ventilation, and air conditioning systems (HVAC) as applicable are functional and unobstructed. Examples include but are not limited to the following:

- a. The HVAC system is operable. (X)
- b. The facilities are ventilated (via mechanical or natural ventilation).
- c. The ventilation units are unobstructed and vents and grills are without evidence of excessive dirt or dust.
- d. There appears to be an adequate air supply to all classrooms, work spaces, and facilities (i.e. no strong odor is present, air is not stuffy)
- e. Interior temperatures appear to be maintained within normally accepted ranges.
- f. The ventilation units are not generating any excessive noise or vibrations.
- g. Other

Sewer

Sewer line stoppage is not evident. Examples include but are not limited to the following:

- a. There are no obvious signs of flooding caused by sewer line back-up in the facilities or on the school grounds. (X)
- b. The sanitary system controls odors as designed.
- c. Other

Interior Surfaces (Floors, Ceilings, Walls, and Window Casings)

Interior surfaces appear to be clean, safe, and functional. Examples include but are not limited to the following:

- a. Walls are free of hazards from tears and holes.
- b. Flooring is free of hazards from torn carpeting, missing floor tiles, holes.
- c. Ceiling is free of hazards from missing ceiling tiles and holes.
- d. There is no evidence of water damage (e.g. no condensation, dampness, staining, warping, peeling, mineral deposits, etc.)
- e. Other

Overall Cleanliness

School grounds, buildings, common areas, and individual rooms appear to have been cleaned regularly. Examples include but are not limited to the following:

- a. Area(s) evaluated is free of accumulated refuse, dirt, and grime.
- b. Area(s) evaluated is free of unabated graffiti.
- c. Restrooms, drinking fountains, and food preparation or serving areas appear to have been cleaned each day that school is in session.
- d. Other

Pest/Vermin Infestation

Pest or vermin infestation are not evident.

Examples include but are not limited to the following:

- a. There is no evidence of a major pest or vermin infestation. (X)
- b. There are no holes in the walls, floors, or ceilings.
- c. Rodent droppings or insect skins are not evident.
- d. Odor caused by a pest or vermin infestation is not evident.
- e. There are no live rodents observed.
- f. Other

Electrical (Interior and Exterior)

1. There is no evidence that any portion of the school has a power failure. (X)

2. Electrical systems, components, and equipment appear to be working properly.
Examples include but are not limited to the following:

- a. There are no exposed electrical wires. Electrical equipment is properly covered and secured from pupil access. (X)
- b. Outlets, access panels, switch plates, junction boxes and fixtures are properly covered and secured from pupil access.
- c. Other

3. Lighting appears to be adequate and working properly, including exterior lights.
Examples include but are not limited to the following:

- a. Lighting appears to be adequate.
- b. Lighting is not flickering.
- c. There is no unusual hum or noise from the light fixtures.
- d. Other

Restrooms

Restrooms in the vicinity of the area being evaluated appear to be accessible during school hours, clean, functional and in compliance with SB 892 (EC Section 35292.5). The following are examples of compliance with SB 892:

- a. Restrooms are maintained and cleaned regularly.
- b. Restrooms are fully operational.
- c. Restrooms are stocked with toilet paper, soap, and paper towels.
- d. Restrooms are open during school hours.
- e. Other

Sinks/Fountains (Inside and Outside)

Drinking fountains appear to be accessible and functioning as intended. Examples include but are not limited to the following:

- a. Drinking fountains are accessible.
- b. Water pressure is adequate.
- c. A leak is not evident.
- d. There is no moss, mold, or excessive staining on the fixtures.
- e. The water is clear and without unusual taste or odor.
- f. Other

Fire Safety

The fire equipment and emergency systems appear to be functioning properly. Examples include but are not limited to the following:

- a. The fire sprinklers appear to be in working order (e.g., there are no missing or damaged sprinkler heads). (X)
- b. Emergency alarms appear to be functional. (X)
- c. Emergency exit signs function as designed, exits are unobstructed. (X)
- d. Fire extinguishers are current and placed in all required areas.
- e. Fire alarms pull stations are clearly visible.
- f. Other

Hazardous Materials (Interior and Exterior)

There does not appear to be evidence of hazardous materials that may pose a threat to pupils or staff. Examples include but are not limited to the following:

- a. Hazardous chemicals, chemical waste, and flammable materials are stored properly (e.g. locked and labeled properly). (X)
- b. Paint is not peeling, chipping, or cracking.
- c. There does not appear to be damaged tiles or other circumstances that may indicate asbestos exposure.
- d. Surfaces (including floors, ceilings, walls, window casings, HVAC grills) appear to be free of mildew, mold odor and visible mold.
- e. Other

Structural Damage

There does not appear to be structural damage that has created or could create hazardous or uninhabitable conditions. Examples include but are not limited to the following:

- a. Severe cracks are not evident. (X)
- b. Ceilings & floors are not sloping or sagging beyond their intended design. (X)
- c. Posts, beams, supports for portable classrooms, ramps, and other structural building members appear to be intact, secure and functional as designed. (X)
- d. There is no visible evidence of severe cracks, dry rot, mold, or damage that undermines the structural components. (X)
- e. Other

Roofs (observed from the ground, inside/outside the building)

Roof systems appear to be functioning properly. Examples include but are not limited to the following:

- a. Roofs, gutters, roof drains, and down spouts are free of visible damage.
- b. Roofs, gutters, roof drains, and down spouts are intact.
- c. Other

Playground/School Grounds

The playground equipment and school grounds in the vicinity of the area being evaluated appear to be clean, safe, and functional.

Examples include but are not limited to the following:

- a. Significant cracks, trip hazards, holes and deterioration are not found.
- b. Open "S" hooks, protruding bolt ends, and sharp points/edges are not found in the playground equipment.
- c. Seating, tables, and equipment are functional and free of significant cracks.
- d. There are no signs of drainage problems, such as flooded areas, eroded soil, water damage to asphalt, or clogged storm drain inlets.
- e. Other

Windows/Doors/Gates/Fences (Interior and exterior)

Conditions that pose a safety and/or security risk are not evident. Examples include but are not limited to the following:

- a. There is no exposed broken glass accessible to pupils and staff. (X)
- b. Exterior doors and gates are functioning and do not pose a security risk. (X)
- c. Windows are intact and free of cracks.
- d. Windows are functional and open, close, and lock as designed, unless there is a valid reason they should not function as designed.
- e. Doors are intact.
- f. Doors are functional and open, close, and lock as designed, unless there is a valid reason they should not function as designed.
- g. Gates and fences appear to be functional.
- h. Gates and fences are intact and free of holes and other conditions that could present a safety hazard to pupils, staff, or others.
- i. Other

PART III: EVALUATION DETAIL Date of Inspection: _____ School Name: _____

CATEGORY	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
AREA	GAS LEAKS	MECH/VAC	SEWER	INTERIOR SURFACES	OVERALL CLEANLINESS	PEST/VERMIN INFESTATION	ELECTRICAL	RESTROOM	SINKS/ FOUNTAINS	FIRE SAFETY	HAZARDOUS MATERIALS	STRUCTURAL DAMAGE	ROOFS	PLAY GROUNDS/ SCHOOL GROUNDS	WINDOWS/ DOORS/ GATES/FENCES	
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															
	COMMENTS:															

Marks: √ = Good Repair; D = Deficiency; X = Extreme Deficiency; NA = Not Applicable
 Use additional Area Lines as necessary.

SCHOOL DISTRICT/COUNTY OFFICE OF EDUCATION		COUNTY	
SCHOOL SITE	SCHOOL TYPE (GRADE LEVELS)	NUMBER OF CLASSROOMS ON SITE	
INSPECTOR'S NAME	INSPECTOR'S TITLE	NAME OF DISTRICT REPRESENTATIVE ACCOMPANYING THE INSPECTOR(S) (IF APPLICABLE)	
TIME OF INSPECTION	WEATHER CONDITION AT TIME OF INSPECTION		

PART III: CATEGORY TOTALS AND RANKING (round all calculations to two decimal places)

TOTAL NUMBER OF AREAS EVALUATED	A. SYSTEMS			B. INTERIOR SURFACES	C. CLEANLINESS	D. ELECTRICAL	E. RESTROOMS/FOUNTAINS		F. SAFETY	G. STRUCTURAL		H. EXTERNAL
	GA8 LEAKS	MECH/HVAC	SEWER				RESTROOMS	SINKS/FOUNTAINS		STRUCTURAL DAMAGE	ROOFS	
Number of V's												
Number of D's												
Number of X's												
Number of N/A's												
Percent of System in Good Repair Number of V's divided by (Total Areas - "N/A's")												
Total Percent per Category (Average of Above)												
Rank (Circle one) GOOD = 80%-100% FAIR = 75%-89.99% POOR = 0%-74.99%												

*Note: An extreme deficiency in any area automatically results in a "poor" ranking for that category and a zero for "Total Percent per Category".

OVERALL RATING: DETERMINE AVERAGE PERCENTAGE OF 8 CATEGORIES ABOVE → **SCHOOL RATING**** →

**For School Rating, apply the Percentage Range below to the average percentage determined above, taking into account the rating Description below.

PERCENTAGE	DESCRIPTION	RATING
99%-100%	The school meets most or all standards of good repair. Deficiencies noted, if any, are not significant and/or impact a very small area of the school.	EXEMPLARY
90%-98.99%	The school is maintained in good repair with a number of non-critical deficiencies noted. These deficiencies are isolated, and/or resulting from minor wear and tear, and/or in the process of being mitigated.	GOOD
75 %-89.99%	The school is not in good repair. Some deficiencies noted are critical and/or widespread. Repairs and/or additional maintenance are necessary in several areas of the school site.	FAIR
0%-74.99%	The school facilities are in poor condition. Deficiencies of various degrees have been noted throughout the site. Major repairs and maintenance are necessary throughout the campus.	POOR

COMMENTS AND RATING EXPLANATION: